

Sponsor

com2C GmbH & co. KG
Gaensekamp 37
32457 Porta Westfalica
Germany

Prepared by

Fire-Lab Sp. z o.o.
Ul. Szałwiowa 9
03-167 Warszawa, Polska

Product name

Silverback 250 PES WBL M W FR

Classification report No.

RKS-3/02/2025

Issue number

Issue no. 1

Date of issue

19.03.2025

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH EN 13501-1:2019

This classification report consists of four pages and may only be used or reproduced in its entirety.

1. Introduction

This classification report defines the classification assigned to Silver 250 PES WBL M W FR in accordance with the procedures given in EN 13501-1:2019.

2. Details of classified product

2.1 General

The following product Silver 250 PES WBL M W FR is defined as decoration and aesthetics, trade fairs and store fixtured and advertising.

2.2 Product description

The product, Silver 250 PES WBL M W FR is described below or is described in the reports provided in support of classification listed in 3.1.

Polyester woven fabric, front side coated with ink receptive coating, back side coated with silver/grey blockout layer "Silver 250 PES WBL M W FR" with total thickness approx. 270µm. The foil consists of:

- ink receptive coating
- PES Farbic
- Silver-grey blockout layer

Specimen tested on metal frame with 4cm gap to calcium silicate substrate

3. Reports and results in support of this classification

3.1 Reports

Name of Laboratory	Name of sponsor	Report ref. no.	Test method and date
Fire-Lab sp z o.o.	com2C GmbH & co. KG	SBI-3/02/2025	PN-EN 13823+A1:2022-12 27.02.2025
Fire-Lab sp z o.o.	com2C GmbH & co. KG	MP-3/02/2025	PN-EN ISO 11925-2:2020 27.02.2025

3.2 Results

Test method and test number	Parameter	No. Tests	Results	
			Continuous parameter mean (m)	Compliance with parameters
PN-EN 13823+A1:2022-12 SBI-3/02/2025	FIGRA _{0,2M} [W/s]	3	0,00	(-)
	FIGRA _{0,4M} [W/s]		0,00	(-)
	LFS < edge		None	Compliant
	THR _{600s} [MJ]		0,88	(-)
	SMOGR _A [m ² /s ²]		0,54	(-)
	TSP _{600s} [m ²]		35,58	(-)
	Flaming droplets/particles		None	Compliant

PN-EN ISO 11925-2:2020 Surface exposure 30s MP-3/02/2025	$F_s \leq 150\text{mm}$	6	$F_s < 150\text{mm}$	Compliant
	Flaming droplets/particles		None	Compliant
PN-EN ISO 11925-2:2020 Edge exposure 30s MP-3/02/2025	$F_s \leq 150\text{mm}$	6	$F_s < 150\text{mm}$	Compliant
	Flaming droplets/particles		None	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with EN 13501-1:2019

4.2 Classification

Products, Silver 250 PES WBL M W FR in relation to its reaction to fire behavior is classified:

B

The additional classification in relations to smoke production is:

s1

The additional classification in relation to flaming droplets / particles is:

d0

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation products is:

Reaction to fire classification: B-s1,d0

4.3 Field of application

This classification is valid for the following parameters defining the product described in point 2.2.

5. Limitations

This classification document does not represent type approval or certification of the product. The assigned classification remains valid as long as:

- The test method will not be changed.
- The product standard or technical approval will not be changed.

- There will be no structural or material changes influencing the properties of the tested material.

SIGNED

APPROVED

signature of person undertaking classification

signature of person authorizing this report